

RFQP 2408FAC

EXHIBIT E

Question to DSA: We have an old admin/classroom building built in the 40s that have windows that are in need of replacement. One option we're looking at is to utilize the COVID relief fund to convert these windows so they are operable thus improve the ventilation/indoor air quality. We envision the upper 1/3 or 1/4 of the window to be either awning or hopper windows. If we do so, then how do we address accessibility requirement?

DSA Response: Yes, a minimum of one window in each room that has new operable windows must comply with 11B-229. Which requires the operating mechanism or controls to be within reach requirements of 11B-305 for clear floor space, 11B-308 for reach requirements and 11B-309.4 for the operation of the mechanism or control.

In addition to that, the window replacement that includes both frame and glazing will trigger 11B-202.4 and the 'Path of Travel' requirements. Glazing alone will not trigger 11B-202.4.

11B-229 Windows

11B-229.1 General. Where glazed openings are provided in accessible rooms or spaces for operation by occupants, at least one opening shall comply with Section 11B-309. Each glazed opening required by an

